

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20151229, Building Permit - Residential
Address: 404 SE MILL CREEK DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mike Copeland	Failed	Wednesday, March 16, 2016

Corrective Action Required

1	Misc 1	-RAISE WATER METER FLUSH WITH GRADE -INSTALL ATTIC ACCESS IN LID IN GARAGE -MOVE WINDOWS TO TEST RECEPTACLE IN GARAGE -INSTALL SECURITY SCREWS ALL REAR DOORS -MAX AC FUSE IS 40 AMP -TOP RISOR STAIRS EXCEEDS 3/8THS IN VARIANCE -INSTALL DECK HANDRAIL
---	--------	--

Plot Plan Inspection	Mike Copeland	Passed	Wednesday, March 16, 2016
-----------------------------	---------------	--------	---------------------------

Comments: