

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20152358, Building Permit - Residential
Address: 3115 SE 3RD TER, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mike Copeland	Failed	Wednesday, March 16, 2016

Corrective Action Required

1	Misc 1	-INSTALL HANGER OVER HVAC CHASE -HAVE FLOOR JOIST LAYOUT ADDRESS FIREPLACE CANTILEVER -FIRESTOP VERTICAL HORZ OPENINGS FUR OUTS -PROTECT NM CONDUCTORS AT ATTIC ACCESS -BOND HYDROTUB MOTOR -MOVE RECEPTACLE HYDROTUB TO ACCOMODATE CORD AND MAKE MOTOR ACCESSABLE
---	--------	---

Electrical Service Inspection - Residential	Mike Copeland	Passed	Wednesday, March 16, 2016
--	---------------	--------	---------------------------

Comments: