

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20152703, Building Permit - Commercial
Address: 123 SE 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Partial	Wednesday, March 16, 2016
Partial Correction 1 Misc 1		OK TO COVER WHEN READY LIGHT-GAUGE STEEL WALL FRAMING + IN-WALL SYSTEMS AT FOLLOWING SPACES: SOUTH FACE OF CROSSWALL AT (6.9) + ALL WALLS SOUTH EXCEPT SPACES [12] & [13];	
Rough Framing Inspection - Commercial	John Borns	Partial	Wednesday, March 16, 2016
Partial Correction 1 Misc 1		EXTERIOR WALL SHEATHING AT [16]: FASTENER PATTERN NOT SPECIFIED ON DRAWINGS, BUT NO ISSUES FOUND ON INSTALLATION SCREWED AT ~ 6" & 8"-10"	

Comments: