

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20160529, Building Permit - Commercial
Address: 2751 NE DOUGLAS ST, Unit:T, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Foundation Inspection - Commercial	Khanh Nguyen	Not Ready	Thursday, March 17, 2016

Corrective Action Required

1	Misc 1	-FORM UP ALL FOOTING AT REAR -REMOVE ALL LOOSE DIRT -PROVIDE MIN. 3" CLEARANCE FROM DIRT TO REBAR
---	--------	---

Comments: