

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20151231, Building Permit - Residential
Address: 405 SE MILL CREEK CIR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mike Copeland	Temporary C of O	Friday, March 18, 2016

Corrective Action Required

1	Misc 1	REPAIR CRUSHED WATER METER WELL. BRING FLUSH WITH GRADE
---	--------	---

Plot Plan Inspection	Mike Copeland	Passed	Friday, March 18, 2016
-----------------------------	---------------	--------	------------------------

Comments: