

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRRES20160494, Building Permit - Residential  
Address: 266 SE COYLE DR, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Residential</b>	John Borns	Passed	Wednesday, March 23, 2016

**Comments: RE-BAR MATS AT ISOLATED FOOTINGS ONLY. WALL FOOTINGS TO BE POURED WITH HELIX REINFORCEMENT MIX. OK TO POUR WHEN READY.**