

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20152357, Building Permit - Commercial  
Address: 471 NW MURRAY RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Final Electrical Inspection - Commercial</b>	John Borns	Failed	Friday, March 25, 2016

### Corrective Action Required

1 Misc 1

GAS-FIRED GENERATOR HAS BEEN INSTALLED WITH:

- 1) NO LICENSED PLUMBING CONTRACTOR LISTED ON PERMIT
- 2) NO RECORD OF INSPECTION OF GAS FEEDER PIPING TRENCHED FROM THRIFT SHOP BUILDING TO GENERATOR
- 3) NO RECORD OF APPROVED PRESSURE TEST ON GAS PIPING
- 4) EXPOSED BLACK IRON GAS PIPE NOT PAINTED PER IFGC 404.8

LATEST INSPECTION REQUEST WAS FOR ELECTRICAL SERVICE. NO REQUEST RECEIVED FOR FINAL INSPECTION.

### Comments: