

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRRES20160412, Building Permit - Residential  
Address: 309 SE MILL CREEK DR, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Piers/Caissons Inspection - Residential</b>	John Borns	Not Ready	Friday, March 25, 2016
<b>Piers/Caissons Inspection - Residential</b>	John Borns	Passed	Friday, March 25, 2016

**Comments: FIVE 24" x 36" MIN PIER HOLES APPROVED FOR POUR -- THREE AT REAR OF HOUSE; TWO AT GARAGE.**