

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20150016, Building Permit - Commercial
Address: 518 NW MURRAY RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	John Borns	Partial	Tuesday, March 29, 2016

Partial Correction
1 Misc 1

OK TO COVER WHEN READY GWB CEILING FRAMING +
ABOVE-CEILING SYSTEMS @ FOLLOWING SPACES: [C105]; [C106];
[102]; [125]; [NORTH STORAGE ROOM @ 2ND FLOOR];

Rated Assembly Inspection	John Borns	Partial	Tuesday, March 29, 2016
--------------------------------------	------------	---------	-------------------------

Partial Correction
1 Misc 1

GWB AT 1 HR FIRE-RATED WALLS: OK TO TAPE, MUD, & FIRE-SEAL
WHEN READY 5/8" TYPE X GWB INSTALLATION @ FOLLOWING
LOCATIONS: WALLS @ [119] & [120]; **WALLS & LID @ [STAIR #1];**

Comments: