

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20151716, Building Permit - Commercial
Address: 401 NE COLBERN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	John Borns	Partial	Wednesday, March 30, 2016
Partial Correction 1 Misc 1		OK FOR TEMPORARY USE & OCCUPANCY AT ALL PHASE AREAS THROUGH APRIL 28, 2016. CALL FOR RE-INSPECTION WHEN READY.	
Corrective Action Required 2 Misc 1		RESOLVE PLANNING DEPARTMENT ISSUES.	
Underslab Plumbing Inspection - Commercial	John Borns	Passed	Wednesday, March 30, 2016
Underslab Electrical Inspection - Commercial	John Borns	Passed	Wednesday, March 30, 2016
Gas Piping Inspection - Commercial	John Borns	Passed	Wednesday, March 30, 2016
In-wall Inspection	John Borns	Passed	Wednesday, March 30, 2016

Comments: ADVISE BUILDING OWNER CODE REQUIRES BACKFLOW PREVENTION DEVICE ON WATER SUPPLY TO COFFEE MAKER.