PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20152440, Building Permit - Residential
Address: 253 SE COYLE DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	John Borns	Failed	Friday, April 01, 2016

Corrective Action Required
1 Misc 1 FIREBLOCK TO ISOLATE VERTICAL CAVITIES FROM HORIZONTAL CAVITIES:
- TOPS OF VERTICAL CHASES AT 1) HOUSE-TO-GARAGE INTERFACE 2) ADJACENT TO LAUNDRY
- WALL CAVITY AT WEST END OF MASTER BATH TUB

Corrective Action Required
3 Misc 1 SOME STUD SHOES NOT FASTENED PER MANUFACTURER INSTRUCTIONS. ENSURE ALL FASTENER HOLES ARE USED AND ALL NAILS ARE FULLY DRIVEN.

Partial Correction
4 Misc 1 OK TO INSULATE

Erosion Control	Mike Copeland	Failed	Friday, April 01, 2016

Corrective Action Required
1 Misc 1 **FULLY RESTORE EROSION CONTROL AT CURB LINE. APPROVAL REQUIRED BEFORE NEXT ALL-ROUGH RE-INSPECTION.**

Comments: