

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20151240, Building Permit - Residential
Address: 428 SE MILL CREEK DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mike Copeland	Failed	Monday, April 04, 2016

Corrective Action Required

1	Misc 1	-MAX FUSE FOR AC UNIT IS 40 AMP, INSTALLED 50 AMP -RAISE WATER METER WELL FLUSH WITH GRADE
---	--------	---

Comments: