

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20150016, Building Permit - Commercial  
Address: 518 NW MURRAY RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

|  |            |          |                         |
|--|------------|----------|-------------------------|
| Inspection:  | Inspector: | Outcome: | Date:                   |
| <b>Water Service<br/>Inspection -<br/>Commercial</b> | John Borns | Passed   | Tuesday, April 05, 2016 |

**Comments: OK TO COVER WHEN READY 2" COPPER TUBING WATER SERVICE INSTALLATION FROM TAP TO BACKFLOW PREVENTION DEVICE/WELL TO METER/WELL SET TO ELEVATION TO CONNECTION TO STUB AT BUILDING ENTRY.**