

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20160657, Building Permit - Residential
Address: 11908 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Residential	John Borns	Passed	Tuesday, April 05, 2016
Final Electrical Inspection - Residential	John Borns	Passed	Tuesday, April 05, 2016

Comments: METALLIC RACEWAY AT G.E.C. APPROACH TO WATER LINE WAS REPLACED TO RESOLVE FOLLOWING CONDITION:

NEC 250.64; T3603.1: METAL RACEWAY ENCLOSING GROUNDING ELECTRODE CONDUCTOR MUST BE ELECTRICALLY CONTINUOUS. BOND EACH END TO G.E.C.

RELEASE ELECTRICAL SERVICE. CLOSE PERMIT.