

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20150016, Building Permit - Commercial  
Address: 518 NW MURRAY RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Underground Plumbing Inspection - Commercial</b>	John Borns	Failed	Tuesday, April 05, 2016

Corrective Action Required  
1 Misc 1

**ANTI-BUOYANCY SLAB NOT INSTALLED ON GREASE INTERCEPTOR PER APPROVED PLUMBING DRAWING. NO OTHER ISSUES FOUND. IF COVER, AT RISK.**

<b>Water Service Inspection - Commercial</b>	John Borns	Passed	Tuesday, April 05, 2016
--	------------	--------	-------------------------

**Comments:**