

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20151897, Building Permit - Commercial
Address: 1201 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	John Borns	Partial	Friday, April 08, 2016

Partial Correction
1 Misc 1

OK TO POUR WHEN READY ISOLATED FOOTINGS:
FOUR TYPE F8; NINE TYPE F6A

Partial Correction
2 Misc 1

ELEVATOR PIT SLAB OK TO POUR WHEN READY

Footing Inspection - Commercial	John Borns	Failed	Friday, April 08, 2016
--	------------	--------	------------------------

Partial Correction
1 Misc 1

OK TO POUR WHEN READY ISOLATED FOOTINGS:
FOUR TYPE F8; NINE TYPE F6A

Corrective Action Required
2 Misc 1

ELEVATOR PIT SLAB RE-BAR: 3" CLEARANCE REQUIRED.

Comments: