

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20151850, Building Permit - Residential

Address: 618 NW WILLOW DR, Unit:C, LEES SUMMIT, MO 64081618 NW WILLOW DR, Unit:B, LEES SUMMIT, MO 64081618 NW WILLOW DR, Unit:A, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	John Borns	Passed	Monday, April 11, 2016

Comments: ALL-SYSTEMS ROUGH IN-WALL AND ABOVE CEILING: OK TO INSULATE AND INSTALL GWB WHEN READY AT: UNIT C; UNIT A; **UNIT B**

COMPLETE ALL WORK IN BASEMENTS BEFORE FINAL INSPECTION.