

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRRES20152158, Building Permit - Residential  
Address: 2400 SW HICKORY LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mike Copeland	Failed	Monday, April 11, 2016

Corrective Action Required

1	Misc 1	-FAILED SIDEWALK INSPECTION, CONTACT PUBLIC WORKS INSPECTIONS. -COULD NOT INSPECT GARAGE RECEPTACLES DUE TO TRASH -MAX FUSE FOR AC 40 AMP -BREAKERS MISSING IN BOTH PANELS -PANELS ARE NOT LABELED CORRECTLY
---	--------	--

<b>Plot Plan Inspection</b>	Mark Harding	Passed	Monday, April 11, 2016
-----------------------------	--------------	--------	------------------------

**Comments:**