

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20151897, Building Permit - Commercial
Address: 1201 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------|--|-------------------------|
| Underslab Plumbing Inspection - Commercial | John Borns | Partial | Tuesday, April 12, 2016 |
| Partial Correction 1 Misc 1 | | OK TO COVER WHEN READY UNDER-SLAB PVC SANITARY DRAIN, WASTE, & VENT PIPING: 6" PVC MAIN BUILDING DRAIN TO OUTSIDE BUILDING LINE + 4" STUB-UPS; NOTE IPC 312 / IRC P2503.5.1 REQUIREMENT FOR PRESSURE-TESTING PIPING SYSTEM. | |
| Footing Inspection - Commercial | John Borns | Partial | Tuesday, April 12, 2016 |
| Partial Correction 1 Misc 1 | | OK TO POUR WHEN READY ISOLATED FOOTINGS: FOUR TYPE F8; NINE TYPE F6A | |
| Partial Correction 2 Misc 1 | | ELEVATOR PIT SLAB OK TO POUR WHEN READY | |
| Partial Correction 3 | | OK TO POUR WHEN READY WALL FOOTINGS & INTEGRAL COLUMN FOOTINGS: FROM e/4.5 TO e/1 TO b/1 TO a/5 TO a/10 TO b/10 TO b/19 TO e/19 TO e/10.5; UFER GROUNDING JUMPER IS IN PLACE AT SOUTHEAST. | |

Comments:

