

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20151744, Building Permit - Commercial  
Address: 2640 NE MCBAINE DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Commercial</b>	John Borns	Partial	Wednesday, April 13, 2016

Partial Correction  
1 Misc 1

PERIMETER FOOTING OK FROM 4/A CLOCKWISE TO SW CORNER OF BUILDING

Partial Correction  
2 Misc 1

**OK TO POUR WHEN READY TWELVE INTERIOR ISOLATED FOOTINGS**

<b>Footing Inspection - Commercial</b>	John Borns	Not Ready	Wednesday, April 13, 2016
--	------------	-----------	---------------------------

Corrective Action Required  
2 Misc 1

OK TO POUR WHEN READY ISOLATED FOOTINGS AT FOLLOWING LOCATIONS: NONE READY -- TOP MAT REQUIRED.

Partial Correction  
1 Misc 1

PERIMETER FOOTING OK FROM 4/A CLOCKWISE TO SW CORNER OF BUILDING

**Comments:**