

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20150816, Building Permit - Residential
Address: 513 NE PROMISED VIEW DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Residential	Khanh Nguyen	Failed	Thursday, April 14, 2016

Corrective Action Required

1	Misc 1	-INDIVIDUAL GAS LINE TO LIGHTS AND OTHER APPLIANCES SHALL BE MINIMUM 8" BELOW FINISHED GRADE, WHERE NOT SUBJECTED TO DAMAGE. EVERYWHERE ELSE, MIN. 12" BELOW GRADE
		**PLASTIC GAS LINE IS ONLY ALLOWED TO BE BURIED. IF IT IS NOT BURIED, THEN YOU MUST CHOOSE OTHER TYPE OF GAS LINE (RIGID GAS PIPE, OR CSST INSTALLED PER MANUFACTURER'S REQUIREMENT)
		**GAS PRESSURE IS AT A LITTLE BELOW 6 PSI. NEED MIN. 10 PSI FOR TESTING

Comments: