

FIRE DEPARTMENT

PLAN REVIEW CONDITIONS

April 15, 2016

GRAY JEFFREY D & MINER KATHRYN S 1805 NW SHAMROCK AVE LEES SUMMIT, MO 64081

Permit No: PRRES20160846

Project Title:

Project Address: 1805 NW SHAMROCK AVE, LEES SUMMIT, MO 64081

Parcel Number: 62130161600000000

Location: HIGHWAY MANOR (L S NEW) LOT 18

Type of Work: ALTERATION SINGLE FAMILY

Occupancy Group: RESIDENTIAL, ONE- AND TWO-FAMILY

Description: ROOF MOUNTED SOLAR - 7.7kW

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please contact the appropriate department regarding clarification of comments.

Codes Administration (816) 969-1200

Fire Department (816) 969-1300

Fire Plan Review Reviewed By: Joe Dir Approved with Conditions

1. 605.11.1 Marking.

Marking is required on interior and exterior direct-current (DC) conduit, enclosures, raceways, cable assemblies, junction boxes, combiner boxes and disconnects.

605.11.1.1 Materials.

The materials used for marking shall be reflective, weather resistant and suitable for the environment. Marking as required in Sections 605.11.1.2 through 605.11.1.4 shall have all letters capitalized with a minimum height of 3/8 inch (9.5 mm) white on red background.

605.11.1.2 Marking content.

The marking shall contain the words "WARNING: PHOTOVOLTAIC POWER SOURCE."

605.11.1.3 Main service disconnect.

The marking shall be placed adjacent to the main service disconnect in a location clearly visible from the location where the disconnect is operated.

605.11.1.4 Location of marking.

Marking shall be placed on interior and exterior DC conduit, raceways, enclosures and cable assemblies every 10 feet (3048 mm), within 1 foot (305 mm) of turns or bends and within 1 foot (305 mm) above and

below penetrations of roof/ceiling assemblies, walls or barriers.

The approval of plans and specifications does not permit the violation of any section of the Building Codes or other City Ordinances or State Law.

The review conducted by the City of Lee's Summit Codes Administration Department shall not be construed as a structural review of the project.