

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20151897, Building Permit - Commercial
Address: 1201 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	John Borns	Partial	Friday, April 15, 2016

Partial Correction
1 Misc 1

OK TO POUR WHEN READY ISOLATED FOOTINGS:
FOUR TYPE F8; NINE TYPE F6A

Partial Correction
2 Misc 1

ELEVATOR PIT SLAB OK TO POUR WHEN READY

Partial Correction
3 Misc 1

OK TO POUR WHEN READY WALL FOOTINGS & INTEGRAL
COLUMN FOOTINGS: FROM e/4.5 TO e/1 TO b/1 TO a/5 TO a/10
TO b/10 TO b/19 TO e/19 TO e/10.5; **e/4.5 TO e/10.5 TO
COMPLETE PERIMETER**

UFER GROUNDING JUMPER IS IN PLACE AT SOUTHEAST.

Comments: