

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRRES20152158, Building Permit - Residential
Address: 2400 SW HICKORY LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Mark Harding		Failed	Friday, April 15, 2016
Codes Residential			

Corrective Action Required

1	Misc 1	-FAILED SIDEWALK INSPECTION, CONTACT PUBLIC WORKS INSPECTIONS.
---	--------	--

Comments: