



April 18, 2016

City of Lee's Summit
220 SE Green Street
Lee's Summit, MO 64063

Sent Via Email

Attn: Mr. Mike Weisenborn

Reference: John Knox Village – Courtyards – Commons Building – 1 HR Rated Porte Cochere Structure
Commercial Final Development Plan – PL2014151

Dear Mike,

We believe the references to fireproofing the steel at the Porte Cochere were erroneously left on the drawings (A6.7) after the switch to VB construction. If you see the need to fireproof these beams, please let us know.

If you have any comments or concerns, please let us know.

Sincerely,

A handwritten signature in black ink, appearing to read 'Daron Speight'.

Daron Speight, AIA
Project Manager/Associate

Pc: Mr. Jim Dunard – Paric
SFCS: ATT