

Inspection Summary

Permit #: PRRES20151850, Building Permit - Residential

Address: 618 NW WILLOW DR, Unit:B, LEES SUMMIT, MO 64081618 NW WILLOW DR, Unit:A, LEES SUMMIT, MO 64081618 NW WILLOW DR, Unit:C, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rated Assembly Inspection	John Borns	Passed	Tuesday, April 19, 2016

Comments: TWO-LAYER FIRE SEPARATION WALLS AT SOUTH & NORTH BOUNDARIES OF UNIT "B" TAPED AND MUDDDED; OK TO COVER WHEN READY.