

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20150016, Building Permit - Commercial  
Address: 518 NW MURRAY RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	John Borns	Partial	Tuesday, April 19, 2016
Partial Correction 1       Misc 1		OK TO COVER WHEN READY GWB CEILING FRAMING + ABOVE-CEILING SYSTEMS @ FOLLOWING SPACES: [C105]; [C106]; [102]; [125]; [NORTH STORAGE ROOM @ 2ND FLOOR]; RAMP[105]; CORRIDOR[110] AFTER INSULATION IS COMPLETED AT NORTH; SOFFITS @ [C107];	
Partial Correction 2       Misc 1		OK TO COVER WHEN READY ACT CEILING FRAMING + ABOVE-CEILING SYSTEMS @ FOLLOWING SPACES: PEDESTRIAN BRIDGE [C205] CORRIDOR ONLY; <b>C-102; C-103; C-104; C-127; R-103;</b>	
<b>Hood/Duct Inspection</b>	John Borns	Partial	Tuesday, April 19, 2016
Partial Correction 1       Misc 1		IMC 506 COMMERCIAL KITCHEN GREASE DUCT FABRICATION & INSTALLATION: LIGHT TEST OF SHOP WELDS OF SEAMS APPROVED; <b>FIELD WELDS OF JOINTS IN PROGRESS;</b>	

**Comments:**