

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRRES20160111, Building Permit - Residential  
Address: 300 SE MILL CREEK DR, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Electrical Service Inspection - Residential</b>	Mike Copeland	Passed	Tuesday, April 19, 2016

<b>All Rough Inspection - Residential</b>	Mike Copeland	Failed	Tuesday, April 19, 2016
---	---------------	--------	-------------------------

Corrective Action Required

1	Misc 1	-FIRESTOP PENETRATIONS IN FIRBLOCKING -UPSTET I BEAM OVER DINING NEEDS MORE THROUGH BOLTS -SECURITY BLOCK BACK DOOR BASEMENT -FUR DOWN BASEMENT TO ACCOMODATE 1/2" GYP IN THE BASEMENT CEILING  OKAY INSULATE
---	--------	--

**Comments:**