

Temporary Certificate of Occupancy

Permit #: PRCOM20151679
Address: 897 NE BLUESTEM DR, LEES SUMMIT, MO 64086
Inspected On: Wednesday, April 20, 2016
Inspected By: Khanh Nguyen
Expiration Date: 12/31/1899 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Temporary C of O	Wednesday, April 20, 2016

Corrective Action Required:

- | | | |
|---|--------|---|
| 1 | Misc 1 | -OBTAIN APPROVAL FROM: FIRE, P&D
-PROVIDE SPECIAL INSPECTION APPROVAL FOR SITEWORK,
CONCRETE, FOOTING STEEL, STRUCTURAL STEEL
-SUBMIT CODE MODIFICATION FOR 400 AMP MAIN PANEL
NON-COMPLIANT WORKING SPACE CLEARANCE
-SECURE THE AMPHITHEATER TRANSFORMER DOWN TO PAD
-PROTECT THE TRANSFORMER FROM VEHICULAR DAMAGE
-AMPHITHEATER HANDRAILS SHALL NOT BE OPEN-ENDED
-PROVIDE HANDRAILS FOR BOTH SIDES OF RAMP AT
AMPHITHEATER
-PLAN CALLS FOR DIMMER SWITCHES FOR STAGE LIGHTING.
RESOLVE THIS WITH DESGINER AND CITY |
|---|--------|---|

