

CODES ADMINISTRATION

Temporary Certificate of Occupancy

Permit #: PRCOM20151679

Address: 897 NE BLUESTEM DR, LEES SUMMIT, MO 64086

Inspected On: Wednesday, April 20, 2016

Inspected By: Khanh Nguyen

Expiration Date: 5/20/2016 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Occupancy Inspection - Khanh Nguyen Temporary C of O Wednesday, April

Codes Commercial 20, 2016

Corrective Action Required:

1 Misc 1 -OBTAIN APPROVAL FROM: FIRE, P&D

-PROVIDE SPECIAL INSPECTION APPROVAL FOR SITEWORK,

CONCRETE, FOOTING STEEL, STRUCTURAL STEEL

-SUBMIT CODE MODIFICATION FOR 400 AMP MAIN PANEL

NON-COMPLIANT WORKING SPACE CLEARANCE

-SECURE THE AMPHITHEATER TRANFORMER DOWN TO PAD -PROTECT THE TRANSFORMER FROM VEHICULAR DAMAGE -AMPHITHEATER HANDRAILS SHALL NOT BE OPEN-ENDED

-PROVIDE HANDRAILS FOR BOTH SIDES OF RAMP AT

AMPHITHEATER

-PLAN CALLS FOR DIMMER SWITCHES FOR STAGE LIGHTING.

RESOLVE THIS WITH DESGINER AND CITY