

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20160269, Building Permit - Commercial
Address: 880 NW BLUE PKWY, Unit:J, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	John Borns	Failed	Thursday, April 21, 2016

Corrective Action Required
1 Misc 1

**SIZE OF EXISTING AND NEW PIPE NOT PER APPROVED
DRAWING. NO WORKMANSHIP ISSUES FOUND. APPROVED
REVISED DRAWINGS REQUIRED. IF COVER AT RISK.**

Underslab Electrical Inspection - Commercial	John Borns	Passed	Thursday, April 21, 2016
---	------------	--------	--------------------------

Comments: