



LEE'S SUMMIT
MISSOURI

CODE MODIFICATION REQUEST
(INSPECTIONS)

BUILDING/STRUCTURE NAME: Legacy Park Amphitheatre

PREMISE ADDRESS: 897 901 NE Bluestem Drive

PERMIT NUMBER (if applicable): PRCOM20151680

OWNER'S NAME: _____

TO: Director of Planning & Codes Administration

In accordance with the Lee's Summit Building Code, I wish to apply for a modification to one or more provisions of the code as I feel that the spirit and intent of the Lee's Summit Building Code are observed the public health, welfare and safety are assured. The following articulates my request for your review and action. (NOTE: ATTACH ANY ADDITIONAL INFORMATION NECESSARY)

I would like to get a modification on Electrical Clearance
or Panel LP3. Due to the size of the room where the panel
is located there are numerous items that conflict with required
clearance space. I would like to put a warning label on the panel informing
workers to shut the panel off at the MDP

SUBMITTED BY:

NAME: Mike Brizzardine

ADDRESS: 1907 Parkwood Dr

CITY, STATE, ZIP: Harrisonville, Mo. 64701

(X) TOWNER () OWNER'S AGENT

Tel.# 816-604-7666

SIGNATURE: [Signature]

6112.26 Working Clearances

MIKE COPELAND - INSPECTION SERVICES DIVISION MANAGER:

(X) APPROVAL

() DENIAL

SIGNATURE: [Signature]

DATE: 4/20/16

ROBERT MCKAY - DIRECTOR OF PLANNING & CODES ADMIN:

(X) APPROVED

() DENIED

SIGNATURE: [Signature]

DATE: 4-20-16

COMMENTS: _____

A COPY MUST BE ATTACHED TO THE APPROVED PLANS ON THE JOB SITE

2/18/14 M:\CODES ADMIN\Forms and Handouts\Codes\Forms\Code Modification Request INSPECTIONS.doc