

---

**PUBLIC WORKS ENGINEERING DIVISION**

## Inspection Summary

---

Permit #: PRRES20152404, Building Permit - Residential

Address: 3337 SW JESSIE CIR, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

**Inspection Item:**

| <b>Inspection:</b>  | <b>Inspector:</b> | <b>Outcome:</b> | <b>Date:</b>           |
|---------------------|-------------------|-----------------|------------------------|
| Driveway Inspection | Brice Lawson      | Partial         | Friday, April 22, 2016 |

**Corrective Action Required**

- 1 There are not any curb cuts or survey stakes to measure from to be sure that the driveway approach is formed at least 1' from the property line. I informed Bill Kenney of this and he will look into it and call for a re-inspection.

|                                         |               |        |                        |
|-----------------------------------------|---------------|--------|------------------------|
| Piers/Caissons Inspection - Residential | Mike Copeland | Passed | Friday, April 22, 2016 |
|-----------------------------------------|---------------|--------|------------------------|

**Comments:**

---