

PUBLIC WORKS ENGINEERING DIVISION

Inspection Summary

Permit #: PRPWFC20160041, Public Works Infrastructure Permit - Commercial
Holiday Inn Express (1201 NW Innovation Pkwy.)FDP
Address: 1201 NW INNOVATION PKWY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection Item:

Inspection:	Inspector:	Outcome:	Date:
PW-Erosion Sediment Control (ESC) Inspection Resolved	Steve Robbins	Passed	Monday, April 25, 2016

1 Your project is in violation of the Erosion and Sediment control policy.

called project manager Steve and asked hime to put rock in the construction entrance and he said he will The rock has been installed in the entrance on 4/22/16

Comments:The issue has been resolved