

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20160190, Building Permit - Commercial
Address: 1100 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Service Inspection - Commercial	John Borns	Failed	Tuesday, April 26, 2016

Corrective Action Required
1 Misc 1

LSCO 7-608: GAS PIPING TEST PRESSURE DECREASED DURING MONITORING PERIOD. CORRECT AND PRESSURIZE PIPING SYSTEM TO HOLD STEADY AT MINIMUM 10 PSI

In-wall Inspection	John Borns	Partial	Tuesday, April 26, 2016
---------------------------	------------	---------	-------------------------

Partial Correction
1 Misc 1

NO ISSUES FOUND ON VISUAL INSPECTION OF NEW & MODIFIED WALL AREAS IN KITCHEN. HOWEVER, GAS PRESSURE TEST MUST BE APPROVED BEFORE COVERING.

Comments: