

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20152703, Building Permit - Commercial
Address: 123 SE 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Hood/Duct Inspection	John Borns	Partial	Wednesday, April 27, 2016
Partial Correction 1 Misc 1		IMC 506 COMMERCIAL KITCHEN GREASE DUCT FABRICATION & INSTALLATION: LIGHT TEST OF SHOP WELDS APPROVED ON FITTINGS: TWO PANT-LEG SECTIONS; TWO REDUCER SECTIONS;	
Above Ceiling Inspection	John Borns	Partial	Wednesday, April 27, 2016
Partial Correction 1 Misc 1		OK TO COVER WHEN READY GWB CEILING FRAMING + ABOVE-CEILING SYSTEMS @ SPACES: CORRIDOR 10/ SERVER STATION 8; WOMEN'S RR 11; MEN'S RR 12: PROVIDE MAINTENANCE ACCESS TO ABOVE-CEILING SPACES	

Comments: