

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20160190, Building Permit - Commercial  
Address: 1100 NE DOUGLAS ST, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Piping Inspection - Commercial</b>	John Borns	Passed	Wednesday, April 27, 2016

**Comments:**

- 1) PRESSURE TEST HELD STEADY ON NEW GAS PIPING AT KITCHEN. APPROVED TO COVER.**
- 2) LIGHT TEST ON GREASE DUCT VERTICAL SECTION: ONE HOLE TO SPOT WELD BEFORE INSTALLING.**