

Temporary Certificate of Occupancy

Permit #: PRCOM20152951
Address: 806 SW BLUE PKWY, LEES SUMMIT, MO 64063
Inspected On: Friday, April 29, 2016
Inspected By: John BornsMichael Weissenbach
Expiration Date: 5/5/2016 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	John Borns	Temporary C of O	Friday, April 29, 2016

Corrective Action Required:

1	Misc 1	NEC 408.4 ELECTRICAL SERVICE PANEL: ENSURE ALL CIRCUIT POSITIONS ARE PROPERLY LABELED. MUST BE LEGIBLE, COMPLETE, CURRENT, SPECIFIC. IF PANEL SCHEDULE IS USED NUMBER POSITIONS ON PANEL FRONT PER SCHEDULE. NO DITTO MARKS OR CONTINUATION SYMBOLS EXCEPT @ MULTIPLE POLE BREAKERS. LABEL UNUSED BREAKERS "SPARE".
---	--------	---

Occupancy Inspection - Fire	Michael Weissenbach	Passed	Friday, April 29, 2016
--	------------------------	--------	---------------------------