

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20160269, Building Permit - Commercial  
Address: 880 NW BLUE PKWY, Unit:J, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>In-wall Inspection</b>	John Borns	Partial	Friday, April 29, 2016

Partial Correction

1 Misc 1

Corrective Action Required

2 Misc 1

**FULL-HEIGHT WALLS OK TO COVER WHEN READY**

**FULLY SCREW ALL FLANGE CONNECTIONS ON TENSION STUDS.  
DO NOT COVER SOFFITS & HANGING BULKHEADS. CALL FOR  
RE-INSPECTION WHEN READY.**

**Comments:**