

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20152703, Building Permit - Commercial
Address: 123 SE 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection - Commercial	John Borns	Partial	Monday, May 02, 2016

Partial Correction

1	Misc 1	ENSURE SERVICE CONDUCTORS ARE COMPLETELY UNDER LUG SCREWS WHEN TORQUED
Corrective Action Required		
2	Misc 1	TIGHTEN G.E.C. CLAMP AT WATER LINE.
Corrective Action Required		
3	Misc 1	PROVIDE GROUND ROD PER APPROVED DRAWING.

Hood/Duct Inspection	John Borns	Partial	Monday, May 02, 2016
-----------------------------	------------	---------	----------------------

Partial Correction

1	Misc 1	IMC 506 COMMERCIAL KITCHEN GREASE DUCT FABRICATION & INSTALLATION: LIGHT TEST OF SHOP WELDS APPROVED ON FITTINGS: TWO PANT-LEG SECTIONS; TWO REDUCER SECTIONS; ONE TRAPEZOIDAL SECTION + ONE REDUCER SECTION;
---	--------	--

Comments: