

PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRCOM20152703, Building Permit - Commercial
Address: 123 SE 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Hood/Duct Inspection	John Borns	Partial	Tuesday, May 03, 2016

Partial Correction
1 Misc 1

IMC 506 COMMERCIAL KITCHEN GREASE DUCT FABRICATION & INSTALLATION: LIGHT TEST OF SHOP WELDS APPROVED ON FITTINGS: TWO PANT-LEG SECTIONS; TWO REDUCER SECTIONS; TWO ADDITIONAL STAIGHT AND REDEUCER SECTIONS; **FIELD WELDS MARKED FOR SPOT-WELDING -- APPLY 1ST LAYER FIRE-WRAP WHEN HOLES ARE SEALED -- THEN REQUEST INSPECTION**

Comments: