

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20161000, Building Permit - Commercial
Address: 517 SW 3RD ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	John Borns	Passed	Tuesday, May 03, 2016
Final Plumbing Inspection - Commercial	John Borns	Passed	Tuesday, May 03, 2016

Comments: OK TO COVER WHEN READY 4" PVC REPLACEMENT OF APPROXIMATELY 7' OF EXISTING C.I. BUILDING DRAIN LINE & CONNECTION TO 3" BRANCH FROM RESTROOMS.