

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20160873, Building Permit - Commercial
Address: 3381 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	John Borns	Partial	Wednesday, May 04, 2016

Partial Correction
1 Misc 1

OK TO POUR WHEN READY ALL INTERIOR ISOLATED FOOTINGS INCLUDING L/5.

Partial Correction
2 Misc 1

OK TO POUR WHEN READY SECTIONS OF CONCRETE GRADE BEAM + INTEGRAL COLUMN FOOTINGS AT: D.1/2 TO D.1/2.8; C/2 TO N/2 TO N/10; **N/10 TO D.1/10 TO D.1/2.8; D.1/9 TO A/9;**

Comments: