

**PLANNING AND CODES ADMINISTRATION DEPARTMENT**  
**220 SE GREEN STREET**  
**LEE'S SUMMIT, MO 64063**  
**(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRRES20152186, Building Permit - Residential  
Address: 3908 NE INDEPENDENCE AVE, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Khanh Nguyen	Partial	Thursday, May 05, 2016

Corrective Action Required

1	Misc 1	-FILL IN WITH SOLID WOOD TO VOID ALONG STRIKE PLATE SIDE, FROM 12" ABOVE THE STRIKE PLATE TO 12" BELOW THE STRIKE PLATE
---	--------	---

**\*\*OK TO ROCK**

**Comments:**