

**PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201**

Inspection Summary

Permit #:PRCOM20151744, Building Permit - Commercial
Address: 2640 NE MCBAINE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Footing Inspection - Commercial	Khanh Nguyen	Partial	Friday, May 06, 2016

Partial Correction
1 Misc 1

PERIMETER FOOTING OK, EXCEPT THE WEST SIDE FROM SW CORNER TO C GRID LINE

Partial Correction
2 Misc 1

OK TO POUR WHEN READY TWELVE INTERIOR ISOLATED FOOTINGS

Comments: