



**LEE'S SUMMIT**  
**MISSOURI**



---

**FIRE DEPARTMENT**

**PLANS REVIEW CONDITIONS**

Permit No:	PRCOM20152703	Date:	May 09, 2016
Project Title:	THIRD STREET SOCIAL	Applicant:	
Location:	123 SE 3RD ST, LEES SUMMIT, MO 64063	PALMER ELECTRIC CO 6600 ROYAL ST, BLDG B PLEASANT VALLEY, MO 64068	
Type of Work:			
Occupancy Group:	A-2	Primary: (816) 415-2252	
Description:	INTERIOR ALTERATIONS FOR FULL SERVICE RESTAURANT PROJECT INCLUDES 562 SF ADDITION FOR STORAGE AND COOLERS		
Construction Type:	Type IIIB (Unprotected)		
Map Page:	195G		

**Listed below are requirements from our department for the project noted above. If you have any additional questions, please contact our department for further clarification.**

**Alarm Plan Review**

**Reviewed By: Joe Dir**

**Released for Construction**

1. 2012 IFC 901.5- Installation acceptance testing. Fire detection and alarm systems, fire-extinguishing systems, fire hydrant systems, fire standpipe systems, fire pump systems, private fire service mains and all other fire protection systems and appurtenances thereto shall be subject to acceptance tests as contained in the installation standards and as approved by the fire code official. The fire code official shall be notified before any required acceptance testing. The fire code official shall be notified 48 hours before any required acceptance test. ACCEPTANCE TESTING WILL BE REQUIRED PRIOR TO THE FINAL OCCUPANCY INSPECTION. TO SCHEDULE A TEST CONTACT THE FIRE DEPARTMENT AT 816-969-1300

**The applicant understands that the requirements listed above must be corrected to conform to applicable City Codes and Ordinances.**