PLANNING AND CODES ADMINISTRATION DEPARTMENT
220 SE GREEN STREET
LEE'S SUMMIT, MO 64063
(816) 969-1200 FAX (816) 969-1201

Inspection Summary

Permit #:PRRES20160412, Building Permit - Residential
Address: 309 SE MILL CREEK DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mike Copeland	Failed	Wednesday, May 11, 2016

Corrective Action Required

1	Misc 1	-FRAME REAR KITCHEN WALL PER S 4.1 -FIRESTOP ELECTRICAL PENETRATIONS TO ATTIC REAR WALL AND DUCT CHASE FIRST FLOOR NEXT TO STAIRS OKA INSULATE

Gas Service Inspection - Residential	Mike Copeland	Failed	Wednesday, May 11, 2016

Corrective Action Required

1	Misc 1	NO PRESSURE

Electrical Service Inspection - Residential	Mike Copeland	Failed	Wednesday, May 11, 2016

Comments: