

**PLANNING AND CODES ADMINISTRATION DEPARTMENT  
220 SE GREEN STREET  
LEE'S SUMMIT, MO 64063  
(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20160269, Building Permit - Commercial  
Address: 880 NW BLUE PKWY, Unit:J, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	John Borns	Partial	Thursday, May 12, 2016

Partial Correction  
1 Misc 1

OK TO COVER WHEN READY GWB CEILING FRAMING +  
ABOVE-CEILING SYSTEMS @ BULKHEADS AND SOFFITS

Partial Correction  
2 Misc 1

**OK TO COVER WHEN READY ACT CEILING FRAMING +  
ABOVE-CEILING SYSTEMS EXCEPT AT WEST 3' OF SERVING AREA:**  
- REMOVE UNUSED BOX CONNECTOR AND PLUG OPENING  
- SECURE MC CABLES WITHIN ~12" OF ENTRY TO BOX

**Comments:**