

Inspection Summary

Permit #: PRCOM20151735, Building Permit - Commercial

Address: 2100 SE BLUE PKWY, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Commercial	Mike Copeland	Failed	Thursday, May 12, 2016

Corrective Action Required

1	Misc 1	-NO CLEANOUTS FOR FIXTURES INSTALLED
---	--------	--------------------------------------

Comments: