

**PLANNING AND CODES ADMINISTRATION DEPARTMENT**  
**220 SE GREEN STREET**  
**LEE'S SUMMIT, MO 64063**  
**(816) 969-1200 FAX (816) 969-1201**

## Inspection Summary

---

Permit #:PRCOM20152703, Building Permit - Commercial  
Address: 123 SE 3RD ST, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Gas Piping Inspection - Commercial</b>	John Borns	Partial	Friday, May 13, 2016
Partial Correction			
1 Misc 1		FINAL CONNECTION YET TO BE COMPLETED TO RTU TO BE SET.	
Corrective Action Required			
2 Misc 1		EXTERIOR EXPOSED PIPE TO BE PAINTED PER IFGC	

<b>Gas Service Inspection - Commercial</b>	John Borns	Passed	Friday, May 13, 2016
--	------------	--------	----------------------

**Comments: GAS PIPING PRESSURE TEST HELD STEADY AT >= 10 PSI FOR >10 MIN. RELEASE GAS SERVICE.**